

Maamba Collieries Limited

Head Office
P.O. Box 99, Maamba, Zambia
Tel:+260 213 278 188, Fax+260 213 278 183
Website:www.maambacoal.com

P.O Box 31197 Lusaka, Zambia Lusaka Office Corporate Park, Plot No. 20849, Alick Nkhata Rd

Telefax:+260 211 256010

12th July, 2024

The Principal Inspector

Zambia Environment Management Agency

P.O. Box 60195

LIVINGSTONE.

Dear Madam,

Re: Submission of Statutory Returns for the period January to June, 2024

statutory returns for the period January to June, 2024 on the attached documents. With reference to the Environmental Management Act of 2011 and the Licensing Regulations of 2013, Maamba Collieries Limited submits the

Yours faithfully,

Yotham M. Phiri

Snr. SHEQ Manager

BI-ANNUAL STATUTORY RETURNS FOR JANUARY TO JUNE 2024

1. AIR AND SOUND PERMITS Table A: Sound - Noise Monitoring

			NOISE LEVE	NOISE LEVEL (dB) FROM MONITORED AREAS	DAREAS		
MONTH	SIPUUMINA	MONTE LEV	WEIGH	AERODROME AREA	MCL HEAD	CHPP	KAZINZE
January 2024	49.6	48.1	57.8	41.3	44.3	68.8	44.3
February 2024	41.5	41.9	44.2	45.5	48.8	53.9	42.5
March 2024	51.6	48.4	55.6	41.9	53.3	51.7	46.7
April 2024	50.2	56.1	45.6	44.2	51.3	57.2	45.3
May 2024	49.4	40.6	57.2	41.9	52.2	56.6	41.8
June 2024	53.3	42.9	57	46.8	47	60.8	35.4
IFC Guidelines	55dB	55dB	85dB (industrial)	85dB (industrial) 85dB (industrial)	85dB (industrial)	85dB	85dB

A sound level meter was used to measure noise during the monitoring periods.

Table B: Air Monitoring –Respirable particulate matter (PM₁₀)

HTNOM	SIPUUMINA	UMINA MONTE LEV WEIGH AERODROME MCL	WEIGH	AERODROME	MCL	CHPP	KANZINZE
	VILLAGE		BRIDGE	AREA (WEST	HEAD		
January 2024	*	*	*	*	*	*	*
February 2024	38.1	19.3	9.1	13.9	34.3	98.3	9.6
March 2024	30.5	27.8	22.6	148.6	19.8	39.8	16.2
April 2024	15.2	24.0	38.0	31.6	24.7	21.3	29.4
May 2024	21.9	45.5	66.4	26.4	22.4	38.0	26.5
June 2024	40.9	68.6	52.6	53.4	40.9	57.5	43.9
ZEMA LIMIT	70µg/m ³	70µg/m ³	70µg/m ³	70µg/m ³	70µg/m³	70µg/m ³	70µg/m³

activities and windy weather during the monitoring period. No. The high PM10 value at AEROUROME and CHPP, in the months of February and March was due to Coal transportation

Note: * No Monitoring was conducted in January 2024 as the Instrument (dustmate) was sent for calibration.

2. EFFLUENT DISCHARGE - UNDERGROUND

follows: -Monthly analysis of the underground water pumped out of Block A Pit Sump into Izuma Stream for the period January to June 2024 is as **A AMUZI**

Table C: Izuma pit A effluent quality

Month	말	Conductivity (uS/cm)	Total Dissolved Solids (mg/l)	Total Suspended Solids (mg/l)	Sulphates (mg/l)	Chlorides (mg/l)	Iron (mg/l)	Manganese (mg/l)
January 2024	3.77	1886	1813	<10	1137.5	5.3	0.905	2.366
February 2024	8.13	1911	1576	<10	934.8	8.8	0.02	1.509
March 2024	8.15	1415	1092	<10	452.8	8.3	0.02	0.843
April 2024	4.82	2322	2119	<10	1204.9	6.6	3.885	2.354
May 2024	8.21	1467	117	<10	513.7	8	0.02	0.596
June 2024	8.29	1340	976	<10	471.4	7.7	0.02	0.443
ZEMA EFFLUENT	6.0-9.0	4300	3000	100	1500	800	2	_

Note: # Means no dewatering was taking place during the month under review.

A monthly grab sample is taken and sent for analysis at an external/independent laboratory in the United Kingdom (Element Materials Technology Lab U.K).

Spikes of Iron and Manganese above guidelines were recorded in January, February and April 2024

The volume of the effluent pumped out from Izuma A pit and discharged into the aquatic environment was estimated to be **1,090,466.67 cubic meters** during the period January to June 2024.

ZUMA B

There was no underground water pumped out of Izuma Block B Pit Sump during the period January to June 2024

Table E: Central Monitoring Basin Emergency Discharge effluent quality

Month	рH	Conductivity (uS/cm)	Total Dissolved Solids (mg/l)	Total Suspended Solids (mg/l)	Sulphates (mg/l)	Chlorides (mg/l)	Iron (mg/l)	Manganes (mg/l)
January 2024	7.06	767	602	<10	225.5	88.4	0.042	0.091
February 2024	7.23	1051	824	<10	258.1	117.4	0.122	0.013
March 2024	7.02	928	782	<10	205.4	103.2	0.141	0.045
April 2024	6.71	826	584	<10	189	98.3	0.02	0.463
May 2024	7.26	847	689	<10	189.1	106.1	0.124	0.054
June 2024	6.98	895	722	<10	191.3	102.2	0.024	0.032
ZEMA EFFLUENT LIMITS	6.0-9.0	4300	3000	100	1500	800	2	_

Note: There was no discharge to the environment during the period under review.

IZUMA OVERBURDEN DUMP WASTE

2024 is as follows: -The quarterly analysis of the ground water from the two monitoring wells around the Izuma B overburden dump for the period January to June

Table F-I: Monitoring Boreholes around waste dumps P2

WHO GUIDELINES FOR DRINKING WATER (1993)	Q2'24	Q1'24	Month
6.5-8.5	10.06	10.13	рН
4000	2569	2627	Conductivity (uS/cm)
1000	1603	1510	Total Dissolved Solids (mg/l)
N/G	12	13	Total Suspended Solids (mg/l)
250	361.4	362	Sulphates (mg/l)
200	41.9	41.6	30
0.3	0.02	0.02	Iron (mg/l)
0.01	0.002	0.002	Manganese (mg/l)

Table F-II: Monitoring Boreholes around waste dumps P3

Month	pН	Conductivity (uS/cm)	Total Dissolved Solids (mg/l)	Total Suspended Solids (mg/l)	Sulphates (mg/l)	Chlorides (mg/l)	Iron (mg/l)	Manganese (mg/l)
Q1'24	8	429	327	<10	24.9	1.5	0.02	0.05
Q2'24	8.1	481	320	<10	20.2	1.1	0.02	0.007
WHO GUIDELINES FOR DRINKING WATER (1993)	6.5-8.5	4000	1000	N/G	250	200	0.3	0.01
Note: N/O moone Not Other or Constitut	م الأدام							

Note: N/G means Not Given or Specified.

Note: NDP Means No Determination Possible.

overburden dumps. Sulphates was above 250 for P2 in Q1 and Q2. Manganese exceeded WHO guidelines for P3 in Q1. A quarterly grab sample is taken and sent for analysis at an external/independent laboratory in the United Kingdom (Element Materials Technology Lab U.K). An alkaline pH of above 10 and Total Dissolved Solids in Q1 and Q2 above 1000mg/l were recorded at P2 behind the

3. DUMP SITES

Table G: Waste on the Dumps

Month				Overbure	Overburden Waste (Tons)	ns)				
	Izuma-A waste	Infill Dump-	Infill Dump-	Overburden Dump	Overburden Dump Dump	Overburden Overburden Dump		Kanzinze waste	Kanzinze	REJECTS (Tons)
	Dump	Izuma-	Izuma-B	(OB1)	(OB2)	(OB3)	(OB4)	Dump	infill Dump	10
		A								
Jan'2024			318,151.29					159,222.05		8,825.96
Feb'2024			446,507.27						230,028.66 9,191.85	9,191.85
Mar'2024			426,809.74						209,179.02	9,205.97
Apr'2024			375,747.04						215,330.20 5,342.32	5,342.32
May'2024			368,746.63						205,761.45 4,984.47	4,984.47
Jun'2024			528,072.02						166,168.34 6,016.64	6,016.64

Note: Overburden means earth layer on top of coal body.

Power Plant. -Rejects means coal grade and quality rejected from the coal washing plant. This coal is currently being used as feed to the Thermal

Table H: Thermal Power Plant ASH

Month	Ash generated (MT)	1000
n-24	64,433	
Feb-24	43,917	
Mar-24	47,368	
Apr-24	52,094	
Mav-24	58,888	
Jun-24	50,729	
Total	317,429	

4. HAZARDOUS WASTE

4.1 USED OILS

Table I: Used oil storage

47,091.68		Grand Total (Site Stock Level)	Grand 7	
89.964.18		Total		
03,140.10		Opening Stock (January 2024)	Openin	
26,818	19,690	3,134	3,994	Sub Total
4891	3,809	452	630	Jun-24
9679	5,015	715	526	May-24
4423	3,096	674	653	Apr-24
3435	1,572	1,293	570	Mar-24
4143	3,374	0	769	Feb-24
3670	2,824	0	846	Jan-24
Total	Suncrest (Liters)	Power Plant (Liters)	MCL (Liters)	MONTHS 2024
USED OILS		USED OILS GENERATED	USE	
	USED OIL GENERATION AND MANAGEMENT	USED OIL GENE		

Used oil at Maamba Collieries is generated from; servicing of Heavy Machines, Trucks, Light vehicles and Thermal power plant. Used oil generated from different areas is then transported to the licensed storage yard for temporal storage before selling to a licensed dealer who does recycling.

4.2 USED LEAD ACID BATTERIES

Table J: Used Lead Acid Batteries Storage

	13,523.66					tock	Closing Stock			
	15,328.46					otal	Grand Total			
	9,165.20					g Stock	Total Opening Stock	To		
1,804.8	6,163.26					(g)	Total (Kg)			
1,804.8	919.2	0	0	92.4	112.7	314	0	348	52	Jun-24
0	1283.16	0	80.26	0	178.1	309.8	365	296	54	May-24
0	991.4	0	0	46.2	161	346	182	200	55.8	Apr-24
0	1038.4	0	26.7	0	124.2	304	182.3	234	167.4	Mar-24
0	1103.1	0	0	88.2	228	335.5	91.2	243	117.2	Feb-24
0	828	0	0	132.3	143	252.1	0	301	0	Jan-24
Sold (kg)		Small	Medium	Large	Small	Medium	Large	Medium	Large	
	Total	Ÿ	Light Duty Batteries	Heavy Duty batteries		/ Batteries	Light Duty Batteries	Heavy Duty Batteries	Heavy Du	
		38)	CREST (KGS)	SUNC			MCL (KG)			Month
		TITY)	ES/QUAN	GENERATED NUMBER OF BATTERIES (SIZES/QUANTITY)	K OF BALL	ED NOMBE	GENERAL			

A total of combined weight of **6,163.26 kilograms** of batteries were generated and **1,804.8** kilograms batteries were sold during the review period. Thus, a combined weight of **13,523.66 kilograms** batteries is still on site as at 30th June, 2024.

Month	Sewer waste generated and transported Mine Site Township faciliti	Township facilities
	11110	
January 2024	172,000	92,000
February 2024	92,000	124,000
	2000	0 4 0
March 2024	104,000	84,000
April 2024	92,000	128,000
May 2024	232,000	104,000
June 2024	236,000	116,000
Total	928,000	648,000
Grand Total	1,:	1,576,000 L

4.4 HEALTH CARE WASTE Table L: Health Care Waste

Total	June 2024	May 2024	April 2024	March 2024	February 2024	January 2024	Month
7.2kgs	1.4	1.5	1.0	0.5	0.8	1.0	Health Care Waste Generated and

NB: Generated health care waste is weighed using a digital scale before transportation.

4.5 PERSONNEL INVOLVED IN MANAGEMENT OF HAZARDOUS WASTE

Personnel involved in Management of hazardous waste underwent medical tests in the period under review. The names are presented in Table M below.

Table M: Personnel involved in the management of hazardous waste and Pesticides and Toxic Substances

S/N	Name	Designation	Hazardous Waste Type	Date Examined	Medical Centre
	Eric Mukando	Mechanic	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
2	Osward Malama	Auto Electrical	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
ω	Adupe kalabila	Vacuum Tanker	Sewer	12-Jan-24	Maamba Hospital High Cost
4	Bwendo Simasiku	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
5	Busiwa Libakeni	Mechanic	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
6	Costain Maguswi	Mechanic	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
7	Dickson Phiri	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
8	Disai syakachoko	Vacuum Tanker	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
9	Hillary Mayabe	Mechanic	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
10	Hillary Simalambo	Mechanic	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
11	Jonathan Kunda	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
12	Kabamba Kalunga	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
13	Kingsley Mweemba	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
14	Lushomo Siabukoko	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
15	Jendo Nyeleti	Vacuum Tanker	Fuel/Oil	12-Jan-24	Maamba Hospital High Cost
16	Brown Jere	Mechanic	Fuel/Oil	13-Jan-24	Maamba Hospital High Cost
17	Joshua Chilete	Mechanic	Fuel/Oil	15-Jan-24	Maamba Hospital High Cost
18	Mcshane Muchiya	Mechanic	Fuel/Oil	15-Jan-24	Maamba Hospital High Cost
		Pesticides and Toxic Substances Handlers	ic Substances Har	ndlers	
21	Boyd Kaleke	Assistant Chemist	DM Plant	21-Feb-24	Maamba Hospital High Cost
21	Gurusamy Mookkiah	Chemical Handler	Water System	19-Feb-24	Maamba Hospital High Cost
22	Haggai Siachibweka	Chemical Handler	DM Plant	26-Feb-24	Maamba Hospital High Cost
23	Isaac Bbalele	Chemical Handler	Water System	19-Feb-24	Maamba Hospital High Cost

30	29	28	27	26	24	24
Venkateswara Rao	Tolla Wanki	Tickley Muchiya	27 Royd Kakene	26 Press Haneya	24 Obrian Mabole	24 Jairon Manyanina
Chemical Handler	Chemical Handler	Chemical Handler	Chemical Handler	Assistant Chemist	Assistant Chemist	Chemical Handler
Water System	Water System	Water System	Raw Water	Water System	DM Plant	Water System
27-Feb-24	21-Feb-24	27-Feb-24	21-Feb-24	19-Feb-24	24-Feb-24	28-Feb-24
Maamba Hospital High Cost						

5. OZONE DEPLETING SUBSTANCES

Table M: Ozone Depleting Substances Usage

Month			Type of R	efrigerant (Kg	J	
	R22	R134a	R410a	R600a	188	R407C
Jan-24	1.8	4	6.18	0.4	NIL.	NE.
Feb-24	2.6	7.8	2.4	NIL		NIL
Mar-24	4.15	8.5	3.03	NIL		NIL
Apr-24	1.2	0.05	7.78	7.78 NIL		NIL
May-24	8	1.5	8.16	1.1		NIL
Jun-24	1.1	6	NIL	0.3		NIL

6. THERMAL POWER PLANT

6.1 Resource consumption (Coal consumption)

Table N: Coal Consumption.

MONTH	BOILER 1-COAL CONSUMPTION (METRIC TONS)	BOILER 2-COAL CONSUMPTION (METRIC
Jan-24	70,995	69,868
Feb-24	32,851	64,456
Mar-24	68,995	37,172
Apr-24	62,087	61,831
May-24	66,401	65,835
Jun-24	59,070	59,680
Total	360,399	358,842

6.2 Air Emissions

Table O: Boiler 1 Emissions

		Apr-24 441.82				Month SO ₂ (mg/Nm ₃)
132.54	108.92	134.47	100.28	63.42	60.13	NO _x (mg/Nm ₃)
44.36	44.82	44.70	67.45	69.83	44.40	Dust (mg/m³)

Note: Spikes of dust emission from February and March, 2024 are attributed to plant startups and stabilization after shut down. The rest of the parameters complied with the emission guide lines.

Table P: Boiler 2 Emissions

Month	SO2 (mg/Nm ₃)	NOX (mg/Nm ₃)	Dust (mg/m3
Jan-24	413.91	54.90	45.57
Feb-24	404.29	47.27	43.43
Mar-24	393.37	60.81	78.51
Apr-24	422.07	95.67	45.64
May-24	419.90	80.94	46.92
Jun-24	419.08	93.29	45.66

Spike of dust emission in March 2024 are attributed to plant startups and stabilization process after shut down.

calculated from hourly readings. The Chimney of the boilers is fitted with an online analyzer. Analysis for air emissions is done hourly. Daily and monthly averages are thus

6.3. PTS Returns

Table Q: PTS Returns - Reservoir Mini-storage

No.	No. Product Name		Stock	Stock Movement		
		Opening stock at beginning of Receipts January, 2024	Receipts	Consumed	Closing stock at 30th June, 2024	Unit (tons
_	Poly Aluminum chloride (PAC)	89.6	45.200	44.075	90.725	tons
N	Cationic polyacrylamide (CPAM)	3.975	0.000	1.255	2.720	tons
ယ	Chlorine (Cl ₂)	2.000	8.000	7.000	3.000	each

Table R: PTS Returns-Thermal Power Plant Main Storage

			Stock N	Stock Movement	
No.	Product Name	Opening stock at beginning of January, 2024	Receipts	Consumed	Closing stock at 30th June, 2024
1	Poly Aluminum chloride (PAC)	0.225	4.8	4.6	0.425
2	Cationic polyacrylamide (CPAM)	0.05	0.075	0.07	0.055
ω	Hydrochloric Acid (HCL)	31.881	12.1	18 681	25.3
4	Sodium Hydroxide (NaOH)	48.33	0	22 05	26.28
5	Hydrazine (N2H4)	38.5	0	0.85	37.65
6	Ammonia (NH3)	1.782	1.495	0.971	2.306
7	Tri sodium Phosphate (TSP)	0.275	0	0.1	0.175
∞	Sulphuric Acid (H2SO4)	47.699	59.34	58.199	48.84
9	Chlorine (CL2)	15	20	30	IJ,
10	INDION 9025	3.8	13.6	5.2	12.2
1	INDION 9062	4.2	13.6	5.8	12
12	INDION 9077	0	0	0	0
3	INDION 9079	1.075	2.400	0.875	2.600
14	INDION 9042	1.000	4.800	2.400	3.400
15	INDION 9210	1.150	2.400	0.950	2.600

6.4 PERSONNEL INVOLVED IN MANAGEMENT OF PTSPersonnel involved in Chemical Management of PTS underwent medical tests in the period under review. Results and medical certificates are yet to be out.

COMPLAINTS REGISTER: There were no complaints received during the period under review. The complaints register is available.